



# FIBER-THERM Installation Manual

FBIM  
9.201

GENERAL INSTALLATION INSTRUCTIONS

2.03.2021

## INSTALLATION INSTRUCTIONS

### UNLOADING & HANDLING

Lift joints from trucks. Pipe slings should be used to unload 8" units or larger. **DO NOT DROP OR DRAG PIPE OFF TRUCK. DO NOT DROP SHARP OR HEAVY OBJECTS ON INSULATED UNITS. DO NOT** use chains or other devices which might puncture insulation jacket.

### STORAGE

Pipe is stockpiled off the ground. Do not exceed a stacking height of 6'. Prevent dirt and debris from entering pipe. Fittings, joining materials, etc. must be stored indoors to protect them from freezing, overheating, moisture, or loss.

### LAYING OF PIPE UNITS – TRENCHING

Lay pipe as close to trench as possible, on the side of the trench opposite of the excavated earth. The trench bed should be 6" of sand. The trench should be smooth and uniform throughout without high spots. All sharp rocks, roots, and other abrasive material must be removed from the trench. If **HARD ROCK** or **SHALE** is encountered, the trench should be excavated 6" greater than necessary, then filled with sand or gravel to act as a cushion on the over-excavated bottom. Sandbags may be used to keep the pipe off the ground to provide a smooth, stable surface, prior to bedding the pipe. Avoid damaging pipe ends. The width of the trench should be two diameters of the insulated supply and return lines plus 1'-6" (one foot six inches). Trench depth will be as indicated on the contract drawings and in line with good construction practices. Trench depth should allow for a minimum cover of 24" on top of the insulated unit.

### FIELD JOINING METHODS (GENERAL\*)

**For all cases, follow the pipe manufacturer's instructions.** The following is meant as a general guideline for **Fiber-Therm NOV RT/GT FRP** 2" thru 6" installation only. Ensure that all taper and bonding surfaces are clean and dry. Remove contaminants with solvents (MEK or Acetone, both **flammable**) or lightly sand with 40 to 120 grit sandpaper. Sand or retaper spigots and sand bells to achieve factory- fresh appearance. Sand or re-taper spigots, and sand bells, to achieve a factory- fresh appearance when surfaced have weathered. Cut 1" of spigot off pipe prior to re-tapering. Wipe sanded socket with clean dry cloth. Do not touch cleaned surfaces with hands because this will cause a deposit of oil and impair proper joint adhesion. Cut pipe to length with hacksaw or abrasive saw; check squareness of cut by inserting pipe shaver arbor flush into cut pipe. **SHAVE PIPE with correct tool!** Before applying adhesive, ensure joint surfaces are dry. Warm with an electric heat blanket or heat gun. **Do not install joint during any rainy weather, since moisture will react poorly in the hardener used in the adhesive. DO NOT TEST FIBER- THERM SYSTEMS WITH GAS OR AIR!**

### READ ADHESIVE INSTRUCTIONS

Thoroughly mix adhesive with hardener according to instructions. Take careful notice of **ADHESIVE WORKING LIFE! DO NOT SPLIT** kits. Mix **all hardener with Adhesive!** If weather is cool (75°F or lower) adhesive may be gently warmed to the touch before hardener is added. Thoroughly mix hardener and adhesive until color is uniform.

### APPROXIMATE WORKING TIME

Adhesive Temperature	75°F / 24°C	Do not use mixed adhesive when it becomes warm and begins to setup.
Pot Life - 8014	15 min.	

### NUMBER OF BONDS PER KIT

Kit Size	2"	3"	4"	6"	8" thru 16"
6.5 oz. adh.	21	15	8	5	see pipe literature
1.0 oz. hardner					

Apply a thin, uniform coating of adhesive to the spigot, spigot end, and deep inside the bell bonding surfaces. Work adhesive into the machined surface, applying pressure during application to "wet out" the machined surface, so that a thin bond line is maintained. **EXCESS ADHESIVE WILL MAKE THE JOINT MORE DIFFICULT TO LOCK! MORE IS NOT BETTER!**

After application of adhesive, insert spigot into bell until surfaces touch; then push and rotate the Fiber-Therm until a lock is achieved. Only a quarter to half turn is usually needed. Pressure should be held against joint to allow entrapped air to escape. A mechanical puller or come along can be used in joint make-up and also hold pressure on joint. Backpressure can be maintained until joint is cured.

Electric heat blankets **MUST** be used for curing adhesive joints. Do not move the pipe joint or fittings until pipe has cooled to the touch- at least two hours.

**NOTE:** Follow detailed instructions from manufacturer of pipe different from the above joint information

### FIELD ALTERATIONS

Pipe will be cut in the field, based on the appropriate field measurements for fittings and/ or making manhole or wall entries. If special lengths are required, measure distance needed for field alteration and cut through unit with hack saw or abrasive wheel. Using factory insulated pipe as guide, cut back insulation. Apply end seals to the clean, dry, exposed insulation surface. Check the squareness of cut with carpenter's square. Remove glassy resin material to bare fiberglass by sanding outer surface. Prepare pipe for joining as described in Field Joining Methods.

### BACKFILL INITIAL

After pipe is installed, specified backfill shall be tamped around the conduit in 6" layers to insure proper compaction. One foot on either side of each joint and fitting shall be left bare for visual inspection during testing.

### TESTING

Sufficient backfill must be placed on pipe and thrust blocks poured and cured, prior to testing. Bleed all air from lines to eliminate possible incorrect readings. The hydrostatic pressure test shall be performed per the engineer's specification with a factory recommendation of one and one-half times the normal operating pressure for not less than two hours. Inspect all fittings, valves, and couplings at this time. **NEVER TEST WITH AIR!** *Appropriate safety precautions shall be taken to guard against possible injury to personnel in the event of a failure.*

### BACKFILL FINAL

Before backfilling is started, the trench should be cleaned of any trench wall cave-ins and general trash. Backfilling should be done with sand 6" below the casing to 6" above. Engineer-approved backfill may be used to fill the rest of the trench. This material should be free of rocks, roots, large clods, or anything that could cause damage to the jacket. Jacket should have a minimum of 2' cover.

**WHEELED OR TRACKED VEHICLES SHALL NOT BE USED FOR TAMPING!**


## THRUST BLOCK INSTALLATION

The engineer who designs the system has the responsibility for designing and sizing the thrust blocks. Knowledge of site soil conditions is essential for proper design. Thermacor will not accept or assume responsibility for thrust blocks, and intends to provide basic data only.

### WHY THRUST BLOCKS?

A Fiber-Therm system must include thrust blocks to prevent any pipe movement from temperature changes. To prevent separation, thrust blocks must be located at:

1. All major changes in direction; i.e., tees and elbows (both horizontal and vertical).
2. All changes in size.
3. All terminal ends.
4. All Valves, so as to support the body weight and prevent excessive torque on pipe connections.
5. **IMPORTANT:** Any connecting metallic pipe must be anchored at the point of connection to the FRP pipe to prevent excessive stresses from being transferred to the FRP pipe.



NOTE: Thrust blocks are required with gasket pipe and solvent weld fittings.


### INSTALLATION

As thrust blocks are an essential part of the system, they should be poured before hydrostatic testing. Temporary thrust blocking may be used with extreme caution if absolutely necessary. The system must be retested after the permanent thrust blocks are poured and cured to verify that the thrust blocks will resist the thrust.


### DESIGN

The design of the thrust blocks depends on test pressure, size, number of pipes, soil conditions, and types of fittings involved. Three conditions must be met for the thrust blocks to function properly.


1. The bearing area must be adequate to resist the pressure force.
2. The bearing surface must rest directly against undisturbed soil.
3. The face of the block bearing surface in the soil must be perpendicular to the resultant direction of thrust.



90° ELBOW



45° ELBOW



REDUCING TEE

If the thrust blocks have not been designed by the engineer, they must be sized by the following procedure:

Example: Design a thrust block to resist the horizontal thrust of two 4" hot water lines (supply and return) at a 90° elbow. The operating temperature of the system is 220° F and the soil is soft clay.

TABLE 1 POUNDS OF THRUST AT FITTING (FORCES ARE ASSUMED THE SAME THRU 250°F)				TABLE 2 SAFE BEARING LOADS	
PIPE SIZE	TEE	90°	45°	SOIL	LB. PER SQ. FT.
2"	2,300	3,250	1,760	Muck, Peat	0
3"	3,300	4,670	2,520	Soft Clay	1,000
4"	5,600	7,900	4,270	Sand	2,000
6"	8,300	11,700	6,350	Sand & Gravel	3,000
8"	12,000	17,000	9,200	Sand & Gravel cemented with clay	4,000
10"	15,000	21,200	11,500	Hard Shale	10,000
12"	17,900	25,400	13,700		

#### STEP 1

#### FINDING THRUST:

From Table 1, the resultant thrust of a 4" x 90° elbow is 7900 lbs.

7900 lbs. x 2 = 15800 lbs. thrust for two elbows.

#### STEP 2 FINDING BEARING AREA OF BLOCK:

From Table 2, soft clay has a bearing strength of 1000 lbs./ sq. ft. therefore:

$$\frac{15800 \text{ lbs.}}{1000 \text{ lbs./ sq. ft.}} = 15.8 \text{ sq. ft. bearing area required}$$

or a block face of 8' x 2' (16 sq. ft.) is adequate.

### THRUST BLOCK TYPES

Examples of thrust blocks for normal fittings are illustrated.

For vertical risers the trench bottom must be undercut, and the entire trench bottom should be covered with concrete. The thrust blocks must bear against firm, stable soil.




FIGURE II




FIGURE I




FIGURE III

### CONSTRUCTION

Thrust blocks are made of concrete.

An acceptable concrete is 1 part Portland cement, 2 parts washed sand, and 3 parts washed gravel with enough water for a relatively dry mix. The dry mix is easier to shape and offers higher strength.

The concrete should be worked thoroughly around the elbows for maximum surface contact. Make sure the entire area between the fittings and the trench wall is filled with concrete and free of voids.

The blocks should be shaped with the designed bearing area against the trench wall. Smaller blocks should be shaped by hand. Larger blocks require simple forms.

The trench should be undercut under the pipes at least six inches to give added thrust resistance and to provide adequate concrete around the fittings. Six inches of concrete should be over the top of the pipe.

The center of the thrust blocks bearing surface should coincide with the horizontal center line of the pipes. (See figures I and II).




FIGURE I





FIGURE II

### UNSTABLE SOIL

If the soil is unstable in the area of a thrust block, it will be necessary for the engineer to make special provisions. This is considered a civil engineering matter and a project civil engineer should be consulted for professional advice.

### VALVE BLOCKS

Blocks must be poured beneath valves with sufficient steel for valve connections. This supports the valve weight and prevents any torque or twisting action caused by opening and closing the valve.



## SHIPPING & HANDLING INSTRUCTIONS

**HANDLE COATED PIPE WITH EXTRA CARE! THIS PIPE CAN DAMAGE WHEN HANDLED, MOVED, OR STORED IMPROPERLY!**

### UPON RECEIPT OF MATERIALS

Make an overall inspection of the load, checking all bands and braces to see if they are intact. Also, check the load for shifting. If the load has shifted, or if the braces and bands are broken, examine each pipe for damage. HAVE THE TRUCK DRIVER MAKE AN ITEMIZED NOTATION OF ANY DAMAGE ON THE DELIVERY RECEIPT AND HAVE IT SIGNED BY THE DRIVER.

### CHECK PACKING LIST

Compare materials received with those listed on the packing list. Count all pipe and boxes. NOTE ANY SHORTAGES ON DRIVER'S DELIVERY RECEIPT.

### CHECK BOXES

Open all boxes and inspect for damages, shortages, and correct size. REPORT ANY DISCREPANCIES WITHIN 30 DAYS AFTER RECEIPT.

### CLAIMS FOR DAMAGES

Claims for damages in transit or lost goods must be made within 30 days. The filing of any claim is the Purchaser's Responsibility. Thermacor will file any claim on Purchaser's behalf upon receipt of the following:

1. Written authority to file such a claim.
2. Written notice of loss or damage (signed and noted Bill of Lading) by truck driver or carrier freight agent.


### UNLOADING PIPE

Pipe may be unloaded by hand or with fork lifts\*, cherry pickers, or cranes. DO NOT HOOK pipe ends. Minimum 4" wide straps or slings should be used.

\*Fork Lift – When using Fork Lift, wide tines or a large surface covering the fork tines must be used to prevent coating damage. Fork Lift must be able to handle the weight of the insulated pipe length.

### PIPE STOCKPILING

Pipe should be stored on level ground, elevated to be as dry as possible, and in such a way that the pipe ends do not lie in water or on the ground. To prevent deformation of the jacket and insulation due to the weight of the pipe, place a series of supports (3 for 20' or 5 for 40') of ample size generally constructed from 2" x 4"s under the pipe as shown below. Supports should increase in width as weight load increases so that the top supports of a fully loaded stockpile should be approximately 10" wide, gradually increasing to the bottom level, approximately 18" wide. Pipe can be pyramided (within reasonable and safe limits) approximately 6' high after a properly braced or chocked base is formed. Pipe stored outside for long periods of time can be covered with blue mesh tarpaulin (plywood can also be used). **Do not prevent airflow as jacket can be deformed from heat buildup.**



**BE VERY CAREFUL NOT TO DROP THE PIPE!**

**NOTE:** Thermacor does not approve of the practice of installing pipe and fittings, and backfilling the pipe before testing. Thermacor will not allow or pay claims for charges which arise in locating and digging up leaks regardless of cause.